
Fire safety risk assessment

Follow the 5 key steps below and fill in the checklist.

The risk assessment process involves an inspection of the premises to identify potential fire hazards, to ensure adequate measures to stop fire starting and that adequate fire protection measures are in place to protect everyone in the building.



1 Fire hazards

- Have you found anything that could start a fire?
- Have you found anything that could burn?
- How could a fire start?
- Think about heaters, lighting, electrical equipment and hot works.
- Have you considered smoking and the use of matches?
- Hot processes, welding and grinding should also be taken into account.

2 People at risk

- Everyone is potentially at risk from fire.
- Think about night staff or people not familiar with the premises, such as visitors or customers.
- Children, the elderly or disabled people are especially vulnerable.
- Who could be at risk?
- Who could be especially at risk?
- 3 Evaluate and act
- Have you assessed the risks in the workplace?
- Do you have enough escape routes?
- Have you planned escape routes?
- Have you made sure people will be able to safely find their way out, even at night?
- Is a fire alarm system needed?
- Are fire exit signs needed and placed?
- Is emergency lighting required?
- Are fire extinguishers needed and, if so, should they be located?
- Have you kept sources of ignition away from fuel sources?
- Have you made sure that everyone safe in case of fire?

- Do you have a fire safety plan?
- Who will be responsible for calling the fire and rescue service?
- Could you put out a small fire and stop it spreading?

4 Record, plan and train

- Have you planned what everyone will do if there is a fire?
- Do all your staff know the plan?
- Have staff had up-to-date training and completed a fire drill?
- Have you included temporary staff?
- Are you maintaining everything that is provided or required to keep people safe from fire?
- Formulate your action plan to reduce the fire hazards. The plan is an inventory of actions, normally prioritised and time constrained to devise, maintain or improve controls. Remember, where appropriate, this can be eliminating or controlling hazards (e.g. better separation of combustible material from ignition sources)

5 Review

- Keep your assessment under regular review. Remember to update it as risks or hazards change. If you make any significant changes, you should review your risk assessment. Have you made any changes to the building since the last assessment?
- Have you had a fire or a near miss?
- Have stock levels change significantly?
- Have you started to store chemical or dangerous substances?

Fire risk assessment checklist

Responsible person (employer or person having control of premises):	
Address of premises:	
Assessor:	
Date of assessment:	
Use of premises:	
Number of floors:	
Building Type:	
Maximum number of employees/visitors:	

Electrical installations and equipment

Are fixed installations periodically inspected and tested every five years?		Yes	No
Are electrical equipment and appliances periodically inspected and tested?	N/A	Yes	No
Is the use of trailing leads and adaptors avoided where possible?	N/A	Yes	No

Smoking

Are adequate measures in place to stop people from smoking on the premises?		Υ	′es	No
Are 'No smoking' signs provided?			Yes	No 🗌
Are suitable arrangements in place for those who wish to smoke outside the premises?	N/	A 🗌	Yes	No 🗌
Arson				
Are the premises adequately secured to prevent unauthorised access?			Yes	No
Are combustible materials, waste and refuse b stored safely clear of the premises or in purpos built compounds/rooms?	N17	A 🗌	Yes	No
Heating systems and portable hea	aters			
Are fixed heating systems subject to periodic maintenance?	N/A		Yes	No
Are portable heaters subject to periodic inspection and used safely?	N/A		Yes	No
Cooking				
Are adequate measures taken to prevent fires from cooking?	N/A		Yes	No
Are filters and ductwork subject to regular cleaning?	N/A		Yes	No

Housekeeping

Is the standard of housekeeping adequate to avoid the accumulation of combustible materials and waste?	Yes	No
Are combustible materials kept separate from ignition and heat sources?	Yes	No 🗌
Is it ensured that all contractors who undertake work on the premises are competent and qualified?	Yes	No 🗌
Dangerous substances		
Are suitable measures in place to address the fire hazards associated with the use and storage of dangerous substances?	/A Yes	No
Other significant fire hazards		
Are there any other significant fire hazards on the premises?	Yes	No

If the answer to the above questions is yes, please list each hazard and any control measures to reduce the likelihood of fire in the box below. If the answer to any question is no, include suitable action within the Action Plan.

Means of escape

Are all escape routes kept clear of obstructions to ensure people escape safely?	Yes		No
Are all fire exits easily and immediately openable?	Yes		No
Are distances of travel considered reasonable?	Yes		No
Are suitable precautions in place for all inner rooms?	N/A	Yes	No 🗌
Is adequate fire protection provided to stairways, including the provision of self-closing, fire-resisting doors?	N/A	Yes	No
Are reasonable arrangements in place for the safe evacuation of any disabled persons on the premises?	N/A	Yes	No

Record brief details of the above measures in the box below. If the answer to any question is no, include suitable action within the Action Plan.

Means of giving warning in case of fire

Is there a suitable electrical fire alarm system?	N/A	Yes	No [
---	-----	-----	------	--

Are automatic smoke/heat detectors provided and is the extent and coverage considered adequate?

N/A	Yes	No	

Record brief details of the above measures in the box below. If the answer to any question is no, include suitable action within the Action Plan.

Manual fire extinguishers

Is there reasonable provision of fire extinguishers? N/A

Emergency escape lighting

Is there a reasonable standard of emergency escape lighting to illuminate escape routes and areas without natural lighting?

N/A	Yes	No
.,,,		

Yes

No

Record brief details of the above measures in the box below. If the answer to any question is no, include suitable action within the Action Plan.

Fire safety signs and notices

Is there a reasonable standard of fire exit signage	N/A	Yes 🗌	No [
and fire safety signs?	,		

Are general fire notices, detailing the action to take in the event of a fire, provided and sited in prominent locations?

N/A	Yes	No

Record brief details of the above measures in the box below. If the answer to any question is no, include suitable action within the Action Plan.

Management of fire safety

Has someone been appointed to manage fire safety?	Y€	es	No
Are procedures in the event of fire appropriate and properly documented?	Ye	es	No 🗌
Are all employees given regular instruction and training on the action to take in the event of a fire?	Ye	es	No 🗌
Are employees with additional responsibilities, such as fire wardens, given additional training to carry out their roles?	N/A	Yes	No
Are daily checks carried out to ensure exit routes are kept clear and fire exits remain easily openable?	N/A	Yes	No
Are monthly and annual testing routines in place for the emergency escape lighting?	N/A	Yes	No
Are weekly testing and periodic maintenance and servicing routines in place for the fire alarm system and any automatic detectors?	N/A	Yes	No
Are fire extinguishers subject to annual maintenance?	N/A	Yes	No
Are records of testing and maintenance maintained?		Yes	No

Record brief details of the above measures in the box below. If the answer to any question is no, include suitable action within the Action Plan.

Action plan

If any of the above boxes are ticked with a 'No', the deficiencies should be described below, along with proposed action for rectification.

Item	Deficiency	Proposed action	Timescale	Person responsible
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				